

# Specificații



Imaginile sunt doar cu titlu informativ



## Eaton 189917

Eaton Moeller® series DILM Contactor, 3 pole, 380 V 400 V 15 kW, 1 N/O, 230 V 50 Hz, 240 V 60 Hz, AC operation, Screw terminals DILM32-10-EA(230V50HZ,240V60HZ)

### General specifications

<b>PRODUCT NAME</b>	Eaton Moeller® series DILM contactor
<b>CATALOG NUMBER</b>	189917
<b>EAN</b>	4015081879137
<b>PRODUCT LENGTH/DEPTH</b>	97 mm
<b>PRODUCT HEIGHT</b>	85 mm
<b>PRODUCT WIDTH</b>	45 mm
<b>PRODUCT WEIGHT</b>	0.42 kg
<b>COMPLIANCES</b>	CE CE Marked RoHS conform
<b>MODEL CODE</b>	DILM32-10- EA(230V50HZ,240V60HZ)

**EATON**

Powering Business Worldwide

## Features Functions

<b>NUMBER OF POLES</b>	Three-pole
------------------------	------------

## Climatic environmental conditions

<b>AMBIENT OPERATING TEMPERATURE - MIN</b>	-25 °C
--------------------------------------------	--------

<b>AMBIENT OPERATING TEMPERATURE - MAX</b>	60 °C
--------------------------------------------	-------

<b>AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN</b>	-25 °C
-------------------------------------------------------	--------

<b>AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX</b>	40 °C
-------------------------------------------------------	-------

<b>AMBIENT STORAGE TEMPERATURE - MIN</b>	-40 °C
------------------------------------------	--------

<b>AMBIENT STORAGE TEMPERATURE - MAX</b>	80 °C
------------------------------------------	-------

## Electrical rating

<b>RATED OPERATIONAL CURRENT (IE) AT AC-1, 380 V, 400 V, 415 V</b>	45 A
--------------------------------------------------------------------	------

<b>RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V</b>	32 A
--------------------------------------------------------------------	------

<b>RATED INSULATION VOLTAGE (UI)</b>	690 V
--------------------------------------	-------

<b>RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ</b>	15 kW
----------------------------------------------------------	-------

## General

<b>CONNECTION</b>	Screw terminals
-------------------	-----------------

<b>OVERVOLTAGE CATEGORY</b>	III
-----------------------------	-----

<b>POLLUTION DEGREE</b>	3
-------------------------	---

<b>PRODUCT CATEGORY</b>	Contactors
-------------------------	------------

<b>VOLTAGE TYPE</b>	AC
---------------------	----

## Electro magnetic compatibility

<b>INTERFERENCE IMMUNITY</b>	According to EN 60947-1
------------------------------	-------------------------

## Magnet system

<b>DUTY FACTOR</b>	100 %
--------------------	-------

<b>RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN</b>	230 V
-------------------------------------------------------------	-------

<b>RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MAX</b>	230 V
-------------------------------------------------------------	-------

<b>RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN</b>	240 V
-------------------------------------------------------------	-------

<b>RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX</b>	240 V
-------------------------------------------------------------	-------

<b>RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN</b>	0 V
------------------------------------------------------	-----

<b>RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX</b>	0 V
------------------------------------------------------	-----

## Contacts

<b>NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)</b>	0
----------------------------------------------------------------	---

<b>NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)</b>	1
--------------------------------------------------------------	---

## Design verification

<b>EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID</b>	6.6 W
-----------------------------------------------------------	-------

<b>HEAT DISSIPATION CAPACITY PDISS</b>	0 W
----------------------------------------	-----

<b>HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID</b>	2.2 W
----------------------------------------------------------	-------

<b>STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS</b>	2.1 W
-----------------------------------------------------------	-------

<b>10.2.2 CORROSION RESISTANCE</b>	Meets the product standard's requirements.
------------------------------------	--------------------------------------------

<b>10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES</b>	Meets the product standard's requirements.
-----------------------------------------------------------------	--------------------------------------------

<b>10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT</b>	Meets the product standard's requirements.
-----------------------------------------------------------------------------------	--------------------------------------------

<b>10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS</b>	Meets the product standard's requirements.
-----------------------------------------------------------------------------------------	--------------------------------------------

<b>10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION</b>	Meets the product standard's requirements.
---------------------------------------------------------	--------------------------------------------

<b>10.2.5 LIFTING</b>	Does not apply, since the entire switchgear needs to be evaluated.
-----------------------	--------------------------------------------------------------------

<b>10.2.6 MECHANICAL IMPACT</b>	Does not apply, since the entire switchgear needs to be evaluated.
---------------------------------	--------------------------------------------------------------------

<b>10.2.7 INSCRIPTIONS</b>	Meets the product standard's requirements.
----------------------------	--------------------------------------------

<b>10.3 DEGREE OF PROTECTION OF ASSEMBLIES</b>	Does not apply, since the entire switchgear needs to be evaluated.
------------------------------------------------	--------------------------------------------------------------------

<b>10.4 CLEARANCES AND CREEPAGE DISTANCES</b>	Meets the product standard's requirements.
-----------------------------------------------	--------------------------------------------

<b>10.5 PROTECTION AGAINST ELECTRIC SHOCK</b>	Does not apply, since the entire switchgear needs to be evaluated.
-----------------------------------------------	--------------------------------------------------------------------

<b>10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS</b>	Does not apply, since the entire switchgear needs to be evaluated.
---------------------------------------------------------------	--------------------------------------------------------------------

<b>10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS</b>	Is the panel builder's responsibility.
----------------------------------------------------------	----------------------------------------

<b>10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS</b>	Is the panel builder's responsibility.
<b>10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH</b>	Is the panel builder's responsibility.
<b>10.9.3 IMPULSE WITHSTAND VOLTAGE</b>	Is the panel builder's responsibility.
<b>10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL</b>	Is the panel builder's responsibility.
<b>10.10 TEMPERATURE RISE</b>	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
<b>10.11 SHORT-CIRCUIT RATING</b>	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
<b>10.12 ELECTROMAGNETIC COMPATIBILITY</b>	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
<b>10.13 MECHANICAL FUNCTION</b>	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## Resurse

CHARACTERISTIC CURVE	<a href="#">eaton-contactors-switch-dilm-characteristic-curve-002.eps</a>
	<a href="#">eaton-contactors-switch-dilm-characteristic-curve.eps</a>
DECLARATIONS OF CONFORMITY	<a href="#">eaton-contactor-declaration-of-conformity-uk251216en.pdf</a>
DESENE	<a href="#">eaton-contactors-dimensions-210t014.eps</a>
INSTRUCȚIUNI DE INSTALARE	<a href="#">IL034042ZU</a>
SCHEME ELECTRICE	<a href="#">eaton-contactors-contact-dilm-wiring-diagram.eps</a>

---

**PROJECT NAME:**

**PROJECT NUMBER:**

**PREPARED BY:**

**DATA:**

---



**Eaton Corporation plc**

Eaton House  
30 Pembroke Road  
Dublin 4, Irlanda  
Eaton.com

Follow us on social media to get the latest product and support information.

