

Specificații



Eaton 190029

Eaton Moeller® series DILM Contactor, 3 pole, 380 V 400 V 4 kW, 1 N/O, 230 V 50 Hz, 240 V 60 Hz, AC operation, Screw terminals DILM9-10-EA(230V50HZ,240V60HZ)

Imaginile sunt doar cu titlu informativ



General specifications

PRODUCT NAME	Eaton Moeller® series DILM contactor
CATALOG NUMBER	190029
EAN	4015081880256
PRODUCT LENGTH/DEPTH	75 mm
PRODUCT HEIGHT	68 mm
PRODUCT WIDTH	45 mm
PRODUCT WEIGHT	0.24 kg
COMPLIANCES	CE CE Marked RoHS conform
MODEL CODE	DILM9-10- EA(230V50HZ,240V60HZ)



Powering Business Worldwide

Features Functions

NUMBER OF POLES	Three-pole
------------------------	------------

General

CONNECTION	Screw terminals
-------------------	-----------------

OVERVOLTAGE CATEGORY	III
-----------------------------	-----

POLLUTION DEGREE	3
-------------------------	---

PRODUCT CATEGORY	Contactors
-------------------------	------------

VOLTAGE TYPE	AC
---------------------	----

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
--	--------

AMBIENT OPERATING TEMPERATURE - MAX	60 °C
--	-------

AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN	-25 °C
---	--------

AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX	40 °C
---	-------

AMBIENT STORAGE TEMPERATURE - MIN	-40 °C
--	--------

AMBIENT STORAGE TEMPERATURE - MAX	80 °C
--	-------

Electro magnetic compatibility

INTERFERENCE IMMUNITY	According to EN 60947-1
------------------------------	-------------------------

Electrical rating

RATED OPERATIONAL CURRENT (IE) AT AC-1, 380 V, 400 V, 415 V	22 A
--	------

RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V	9 A
--	-----

RATED INSULATION VOLTAGE (UI)	690 V
--------------------------------------	-------

RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ	4 kW
--	------

Short-circuit rating

SHORT-CIRCUIT CURRENT RATING (BASIC RATING)	5 kA, 30 A max. fuse, SCCR (UL/CSA) 5 kA, 30 A max. CB, SCCR (UL/CSA)
--	--

SHORT-CIRCUIT CURRENT RATING (HIGH FAULT AT 480 V)	100 kA, 20 A CLASS J max. fuse, SCCR (UL/CSA) 30 kA, 25 A CLASS RK5 max. fuse, SCCR (UL/CSA) 65 kA, 16 A max. CB, SCCR (UL/CSA)
---	---

SHORT-CIRCUIT CURRENT RATING (HIGH FAULT AT 600 V)	100 kA, 20 A CLASS J max. fuse, SCCR (UL/CSA) 30 kA, 25 A CLASS RK5 max. fuse, SCCR (UL/CSA)
---	---

Magnet system

DUTY FACTOR	100 %
--------------------	-------

RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN	230 V
---	-------

RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MAX	230 V
---	-------

RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN	240 V
---	-------

RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX	240 V
---	-------

RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN	0 V
--	-----

RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX	0 V
--	-----

Contacts

NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
--	---

NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	1
--	---

Design verification

10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
10.10 TEMPERATURE RISE	The panel builder is responsible for the

Resurse

CHARACTERISTIC CURVE	eaton-contactors-switch-dilm-characteristic-curve-002.eps eaton-contactors-switch-dilm-characteristic-curve.eps
DECLARATIONS OF CONFORMITY	eaton-contactor-declaration-of-conformity-uk251210en.pdf
DESENE	eaton-contactors-module-dilm-dimensions-002.eps eaton-contactors-module-dilm-dimensions.eps eaton-contactors-frame-dilm-dimensions.eps eaton-contactors-dilm-3d-drawing-007.eps
INSTRUCȚIUNI DE INSTALARE	IL034041ZU
SCHEME ELECTRICE	eaton-contactors-contact-dilm-wiring-diagram.eps

	temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATA:



Eaton Corporation plc
 Eaton House
 30 Pembroke Road
 Dublin 4, Irlanda
 Eaton.com

Follow us on social media to get the latest product and support information.

